



MIZORAM RURAL BANK
HEAD OFFICE , AIZAWL, MIZORAM

e-mail : fa@mizobank.com

TENDER

Date : 01/07/2021

FOR

**SUPPLY,INSTALLATION,TESTING AND COMMISSIONING OF 15KVA & 25KVA
DIESEL GENERATOR SET FOR MIZORAM RURAL BANK**

Submission Start Date : 01-07-2021 11:00AM
Last date for Submission of Tender : 01-08-2021 3:00PM
Opening of Tender : 01-08-2021 3:30 PM

**The General Manager,
Mizoram Rural Bank,Head Office
Babu Tilla, Zarkawt, Aizawl
Mizoram 796007**



NOTICE INVITING TENDER

Mizoram Rural Bank invites tender for supply ,installation, testing and commissioning of 2nos. of 15KVA & 1no. of 25KVA Diesel Generator set for Marpara Branch,Phullen Branch and Champhai Branch. Interested parties are requested to submit the bids/quote for the aforesaid works as per detailed specifications and requirements as mentioned below:

Sl. no	Branch	KVA	Quantity	Phase	Specifications	RATE (Including,Transportation,installation,Commissioning etc.)
	CHAMPHAI BRANCH	25 KVA	1	1	Supply, installation, testing and commissioning of Diesel Generating Set having prime power of 25 kVA, Single Phase. The machine shall have capability to run continuously in variable load condition for unlimited hours and should have 10% overload capacity of one hour in every 12 hours of operation. Diesel engine shall be direct Injection Water Cooled, 4 strokes, 1500 RPM of suitable BHP Capable of giving above mentioned output of Alternator. Engine will be fitted with all the required accessories. The engine shall be capable of taking an overload of 10% intermittently for one hour in every 12 hours of operation and the engine shall conform to IS:10000/ISO, 3046/BS, 649/BS 5514 Starting System & Accessories: 12 V Electric Starter Battery Charging Alternator Charge Indicating Ammeter 1x12 Volt 90 AH Battery, Engine Protection Unit with Fuel on Solenoid. Alternator capable of delivering 25 KVA at 0.8 power factor i.e. 20 KW, 230 Volts, 50 Hz frequency. MCB/MCCB TP of 40 Amp rating DG Controller of Procom make for indication of Voltage, Current, Frequency, Lube Oil Pressure, Coolant Temperature, Fuel Level etc DC Ammeter, Push Button for engine start/stop, Control Wiring	
2	MARPARA BRANCH	15KVA	1		Supply, installation, testing and commissioning of Diesel Generating Set having prime power of 15 kVA, Single Phase. The machine shall have capability to run continuously in variable load condition for unlimited hours and should have 10% overload capacity of one hour in every 12 hours of operation.	

				1	Diesel engine shall be direct Injection Water Cooled, 4 strokes, 1500 RPM of suitable BHP Capable of giving above mentioned output of Alternator. Engine will be fitted with all the required accessories. The engine shall be capable of taking an overload of 10% intermittently for one hour in every 12 hours of operation and the engine shall conform to IS:10000/ISO, 3046/BS, 649/BS 5514 Starting System & Accessories: 12 V Electric Starter Battery Charging Alternator Charge Indicating Ammeter 1x12 Volt 90 AH Battery, Engine Protection Unit with Fuel on Solenoid. Alternator capable of delivering 15 KVA at 0.8 power factor i.e. 12 KW, 230 Volts, 50 Hz frequency. MCB/MCCB TP of 63 Amp rating DG Controller of Procom make for indication of Voltage, Current, Frequency, Lube Oil Pressure, Coolant Temperature, Fuel Level etc DC Ammeter, Push Button for engine start/stop, Control Wiring.	
3	PHULLEN BRANCH	15KVA	1	1	Supply, installation, testing and commissioning of Diesel Generating Set having prime power of 15 kVA, Single Phase. The machine shall have capability to run continuously in variable load condition for unlimited hours and should have 10% overload capacity of one hour in every 12 hours of operation. Diesel engine shall be direct Injection Water Cooled, 4 strokes, 1500 RPM of suitable BHP Capable of giving above mentioned output of Alternator. Engine will be fitted with all the required accessories. The engine shall be capable of taking an overload of 10% intermittently for one hour in every 12 hours of operation and the engine shall conform to IS:10000/ISO, 3046/BS, 649/BS 5514. Starting System & Accessories: 12 V Electric Starter Battery Charging Alternator Charge Indicating Ammeter 1x12 Volt 90 AH Battery, Engine Protection Unit with Fuel on Solenoid. Alternator capable of delivering 15 KVA at 0.8 power factor i.e. 12 KW, 230 Volts, 50 Hz frequency. MCB/MCCB TP of 63 Amp rating DG Controller of Procom make for indication of Voltage, Current, Frequency, Lube Oil Pressure, Coolant Temperature, Fuel Level etc DC Ammeter, Push Button for engine start/stop, Control Wiring.	

Bid Submission Configuration

Mode of Bid submission	: Offline	Bidding access	: Open
Base currency	: INR		
Consortium	: N/A	Bid withdrawal	: Allowed

Eligible Taxes

1. Contractor should have GST Registration Number.
2. Rates quoted should be inclusive of all taxes & duties and levies, including Goods & Services Tax (GST) . .
3. In case of correction in the bills after scrutiny, contractor should submit fresh bills for payment.
4. Contractor should timely file his GST return in accordance with GST provisions to enable the bank to claim the credit of GST paid to the contractor.

Terms of Payment of Bills

1. No Advance will be paid
2. No RA Bill will be entertained and the final Bill will be paid on satisfactory completion of the works as per measurement of actual quantity
3. The bill may be submitted to **"The Chairman, Mizoram Rural Bank, Head Office, MINECO, Khatla, Aizawl, Mizoram"** for payment of bills after complete and satisfactory delivery of the item.
The GST number of MIZORAM RURAL BANK :GSTIN 15AAAAM1725F123

**FORM OF SUBMISSION OF TENDER
(To be filled by the tenderer)**

**The General Manager,
Mizoram Rural Bank,
Head Office, Babu Tilla,
Zarkawt, Aizawl ,
Mizoram 796007**

Dear Sir/Madam,

SUBJECT : TENDER FOR SUPPLY, INSTALLATION, TESTING AND COMMISSIONING OF 15KVA & 25KVA DIESEL GENERATOR SET FOR MIZORAM RURAL BANK

I/ We hereby declare that I/ We have carefully gone through the conditions laid down in the Notice Inviting Tender, specifications and clearly understood all the same and on the basis of the same I/We quoted our rates with the tender notice.

I / We do here by undertaken to execute and complete the whole or part of the work (as desired by you) at the respective rates quoted(Enclosed).

In the event of this Tender being accepted I / We further agree to complete the work included in the said estimates within _____ days from the date of the work order issued to commence the same.

I / We agree not to employ sub-contractors other than those that may be approved by Employer. I / We agree to pay all taxes, charges as prevailing from time to time, on such items for whom same is to be levied by/ for the government, and the rates quoted by me / us are inclusive of all the same.

Yours Faithfully,

Contractor's Signature : _____

Name : _____

Address: : _____

DATED: __/__/____

Signature of Witness: 1. _____

2. _____

(Signature of the Tenderer)